

COS

Mounting & Wiring

Installation Instructions

For use with the Sage central battery system

A) MOUNTING METHODS

TOP / END / BACK MOUNT

Fit the die-cast aluminum canopy to the sign's top, end or back as the location requires, mount the canopy over the J-box and route the low voltage run through it.

LEGEND AND ARROWS

Confirm the exit or stair legend and the arrow configuration ordered against the egress layout before mounting; universal signs take single or double face in the field.

B) WIRING & SYSTEM TEST

1. Turn off the central battery branch circuit before installation. All wiring per NEC and local code; the low voltage run is Class 2.
2. Connect the run conductors from the Sage central battery to the sign, observing polarity per the circuit layout and the Sage central battery installation guide. There is no AC connection and no battery at the sign.
3. Close the housing, energize the central battery circuit and verify that the sign is lit in normal service and in emergency transfer.
4. Inspection: check the panel, the legend and the mounting as local practice requires.

SAVE THESE INSTRUCTIONS

“Engineered for the spaces it protects.”