

NIM

Mounting & Wiring

Installation Instructions

For use with the Sage central battery system

A) MOUNTING METHODS**WALL MOUNT**

Fix the die-cast mounting brackets to the wall with fasteners suited to the structure and mount the housing on the brackets; bring the low voltage run in through the conduit hub with the wiring method the location requires.

CONDUIT OR PENDANT MOUNT

Mount the sign on the pre-installed conduit hub, on conduit or on the custom-length pendant (PENX); keep the gasket seated and close the lens with the stainless steel screws; snap out the chevron indicators the egress direction requires.

B) WIRING & SYSTEM TEST

1. Turn off the central battery branch circuit before installation. All wiring per NEC and local code; the low voltage run is Class 2.
2. Connect the run conductors from the Sage central battery to the sign, observing polarity per the circuit layout and the Sage central battery installation guide. There is no AC connection and no battery at the sign.
3. Close the housing, energize the central battery circuit and verify that the sign is lit in normal service and in emergency transfer.
4. Inspection: check the panel, the legend and the mounting as local practice requires.

SAVE THESE INSTRUCTIONS*“Engineered for the spaces it protects.”*